


Summary

\$7,031 Monthly Energy Cost Savings	28,380 Elec. Savings (kWh/mo)	6% Elec. Savings (%)	349,451 R12M Electricity Savings (kWh/yr)	5,228 CO2e Savings (kg/mo)
\$124,217 R12M Energy Cost Savings	7,296 Gas. Savings (kWh/mo)	9% Gas. Savings (%)	872,996 R12M Gas Savings (kWh/yr)	234,903 R12M CO2e Savings (kg/yr)

Total Energy (kWh/Month)






Summary




Energy Cost for the Month (\$) \$122.907 \$1,843 **Site Name** \$2,422 (2%) -(1%) Aquatic Centre \$3,366 (3%) Water Treatment Plant \$3,433 (3%) \$37,721 (30%) Braemar Rd Pumps \$3,569 (3%) Paul Rd Pumps \$4,437 (4%) Whakatane Oxidation Ponds Te Koputu Library \$10,918 (9%) Ohope Oxidation Ponds Johnson Rd Pumps Museum Research Centre \$11,001 (9%) Civic Centre Bridger Glade Pumps \$27,541 (22%) McAlister and Rose Garden Pumps \$12,276 (10%) War Memorial Hall





Summary


Cumulative Energy Savings (kWh)




Note, cumulative savings are calculated starting July 2018



Summary



Note, cumulative savings are calculated starting July 2018





Civic Centre

\$6,786	32,138	88%	220,960	4,210
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
\$40,421				28,272
R12M Energy Cost Savings				R12M CO2e Savings (kg/yr)


Comments:

The baseline for the Civic Centre has been updated, the baseline period was selected as Dec-2020 to Nov-2021, in order to exclude months where refurbishment was taking place.

Electricity use continues to be less than baseline for 2022, the Civic Centre renovation has displaced many office workers, which has decreased electricity demand. Billing and usage has been updated for the Civic Centre, which was previously not billed for several months.

Electric vehicle charging stations have been in use from March 2021, non-routine adjustments are on-going to account for the increased electricity use.


Civic Centre Electricity Use Compared to Baseline (kWh)






Civic Centre






Civic Centre Rolling 12 Month Savings





Civic Centre





● EUI Monthly (kWh/year/m^2) ● EUI R12M (kWh/year/m^2)



Aquatic Centre


-\$893 Monthly Energy Cost Savings	-7,871 Elec. Savings (kWh/mo)	-6% Elec. Savings (%)	-43,899 R12M Electricity Savings (kWh/yr)	1,221 CO2e Savings (kg/mo)
\$54,075 R12M Energy Cost Savings	10,881 Gas. Savings (kWh/mo)	17% Gas. Savings (%)	898,068 R12M Gas Savings (kWh/yr)	189,498 R12M CO2e Savings (kg/yr)

Comments:

Electricity and natural gas baselines have been updated for the Aquatic Centre, the baseline period is May 2021 to June 2022 and excludes Aug. and Sept. 2021 due to changes in Covid-19 alert levels and partial closure. The outdoor pool is open year-round and the baseline reflects this change.

More electricity was used than expected when compared to the new baseline, however, 17% less natural gas was used in August 2022. The monthly EUI in August 2022 is approximately 4% less than it was in August 2021.


Rolling 12 month savings are decreasing, and will continue to decrease as a result from savings being measured against the new baseline. Savings can be increased by implementing new energy saving initiatives.






Aquatic Centre

Aquatic Centre Natural Gas Compared to Baseline (kWh)





Aquatic Centre Carbon Emissions Compared to Baseline (kg CO2e)





Aquatic Centre








Te Koputu Library

-\$390 Monthly Energy Cost Savings	-1,144 Elec. Savings (kWh/mo)	-10% Elec. Savings (%)	17,410 R12M Electricity Savings (kWh/yr)	- 541 CO2e Savings (kg/mo)
-\$52	- 1,888 Gas. Savings (kWh/mo)	- 19%	-41,797	-6,710
R12M Energy Cost Savings		Gas. Savings (%)	R12M Gas Savings (kWh/yr)	R12M CO2e Savings (kg/yr)

Comments:

New baselines were established for electricity and natural gas at the Library, the baseline period is July 2021 to June 2022 and use cooling degree days as the independent variable.


Natural gas use has increased by 34% compared to August 2021, electricity use has increased by 21%, however, August 2022 was a warmer month on average. Dehumidification loads are significant, electricity is required for cooling and gas is required for re-heat. Control of relative humidity has improved, however further investigation is needed to understand if this is optimised or if the cooling and heating coils are fighting each other excessively.






Te Koputu Library













Te Koputu Library











Museum and Research Centre


-\$137 Monthly Energy Cost Savings	-727 Elec. Savings (kWh/mo)	-8% Elec. Savings (%)	12,390 R12M Electricity Savings (kWh/yr)	-32 CO2e Savings (kg/mo)
\$4,442 R12M Energy Cost Savings	304 Gas. Savings (kWh/mo)	10% Gas. Savings (%)	34,765 R12M Gas Savings (kWh/yr)	9,127 R12M CO2e Savings (kg/yr)

Comments:

New baselines were established for electricity and natural gas at the Museum and Research Centre, the baseline period is July 2021 to June 2022. The electricity baseline uses cooling degree days as the independent variable and the natural gas baseline uses heating degree days as the independent variable.

Electricity use was more than expected and natural gas was less than expected. Afterhours electricity use was elevated from the 10-14 and 29-31 of August.


Museum Research Centre Electricity Use Compared to Baseline (kWh)






Museum and Research Centre

Museum Research Centre Natural Gas Compared to Baseline (kWh)





Museum Research Centre Carbon Emissions Compared to Baseline (kg CO2e)






Museum and Research Centre





Museum Research Centre Rolling 12 Month Savings





War Memorial Hall


\$585 Monthly Energy Cost Savings	3,335 Elec. Savings (kWh/mo)	39% Elec. Savings (%)	27,909 R12M Electricity Savings (kWh/yr)	23 CO2e Savings (kg/mo)
\$2,835 R12M Energy Cost Savings	-2,001 Gas. Savings (kWh/mo)	-63% Gas. Savings (%)	-18,040 R12M Gas Savings (kWh/yr)	-218 R12M CO2e Savings (kg/yr)

Comments:

The baseline was updated for War Memorial Hall, the baseline adjusts for ambient temperature. The baseline period is July 2021 to June 2022. The War Memorial Hall uses more electricity and gas in winter months.

Natural gas use has been significantly more than expected for May to August 2022. It would be good to understand if any changes have been made to HVAC controls, or if the number of events and bookings has increased from May 2022. Overall, total energy use by the facility is less than baseline and a small carbon savings has been achieved for the month.


The War Memorial Hall is on a NHH account, some months' usage may be estimated by the retailer and captured by a subsequent meter reading. It is recommended that manual meter readings are taken, which would improve accuracy of electricity and gas usage.






War Memorial Hall

War Memorial Hall Natural Gas Compared to Baseline (kWh)




War Memorial Hall Carbon Emissions Compared to Baseline (kg CO2e)






War Memorial Hall

War Memorial Hall Energy Use Index by Month Compared to Rolling 12-Month Values







Water Treatment Plant


\$1,774	8,439	7%	-15,739	1,105
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
-\$1,934				-1,988
R12M Energy Cost Savings				R12M CO2e Savings (kg/yr)

Comments:

The electricity use baseline was updated for the Water Treatment Plant, the baseline period is July 2021 to June 2022. The electricity baseline uses the amount of water pumped (m³) as the independent variable.

A 7% savings has been achieved at the WTP this month. The volume of water treated and total electricity use has decreased compared to August 2021. The monthly EUI is less than the average over the last 12 months, which is good.








Water Treatment Plant

Water Treatment Plant Carbon Emissions Compared to Baseline (kg CO2e)




Water Treatment Plant Rolling 12 Month Savings





Water Treatment Plant

Water Treatment Plant Energy Use Index by Month Compared to Rolling 12-Month Values



● EUI Monthly (kWh/m^3) ● EUI R12M (kWh/m^3)




Braemar Road Pump Station

-\$63	-293	-1%	77,275	-38
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
\$10,955 R12M Energy Cost Savings				10,108 R12M CO2e Savings (kg/yr)

Comments:

The electricity use baseline was updated for the Braemar Road Pump Station, the baseline period is July 2021 to June 2022. The electricity baseline uses the amount of water pumped (m³) as the independent variable.


Savings from the high efficiency pumps and motors will no longer be visible when comparing to the new baseline, however, real savings have been achieved since September 2020, using approximately 15% less electricity compared to the older pumps and motors.






Braemar Road Pump Station











Braemar Road Pump Station





● EUI Monthly (kWh/m^3) ● EUI R12M (kWh/m^3)




Paul Road Pump Station

\$423 Monthly Energy Cost Savings	1,944 Elec. Savings (kWh/mo)	5% Elec. Savings (%)	-18,293 R12M Electricity Savings (kWh/yr)	255 CO2e Savings (kg/mo)
-\$2,473 R12M Energy Cost Savings				-2,340 R12M CO2e Savings (kg/yr)

Comments:

The electricity use baseline was updated for the Paul Road Pump Station, the baseline period is July 2021 to June 2022. The electricity baseline uses the amount of water pumped (m³) as the independent variable. The updated baseline has a smaller baseload factor and a larger variable component.


A moderate savings has been achieved at the Paul Road Pump Station this month. The monthly EUI is less than average over the past 12 months, which is excellent.






Paul Road Pump Station










Paul Road Pump Station





● EUI Monthly (kWh/m^3) ● EUI R12M (kWh/m^3)




Johnson Road Pump Station

\$307	1,391	11%	30,609	182
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
\$6,749				3,951
R12M Energy Cost Savings				R12M CO2e Savings (kg/yr)

Comments:


The electricity use baseline was updated for the Johnson Road Pump Station, the baseline period is Aug 2018 to June 2022. The electricity baseline uses the amount of water pumped (m³) as the independent variable. The updated baseline has a smaller baseload factor and a larger variable component.


Johnson Rd Pumps Electricity Use Compared to Baseline (kWh)





Johnson Road Pump Station







Johnson Road Pump Station

Johnson Rd Pumps Energy Use Index by Month Compared to Rolling 12-Month Values



● EUI Monthly (kWh/m^3) ■ EUI R12M (kWh/m^3)



Johnson and Braemar Rd Pump Stations


\$244	1,098	2%	107,884	144
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
\$17,704				14,059
R12M Energy Cost Savings				R12M CO2e Savings (kg/yr)

Comments:

Baselines were updated for Johnson Road and Braemar Road pump stations.

It is clear from the combined monitoring how the new, more efficient pumps (installed September 2020) at Braemar Road greatly contribute to the collective savings. On an EUI basis, even before the more efficient pumps were installed, Braemar Road was pumping water more efficiently than Johnson Rd.


Johnson Rd achieved savings in August 2022, Braemar Rd pump station used 1% more electricity than expected.






Johnson and Braemar Rd Pump Stations

Johnson and Braemar Rd Pump Stations Carbon Emissions Compared to Baseline (kWh)








Johnson and Braemar Rd Pump Stations

Johnson and Braemar Rd Pump Stations Energy Use Index by Month





Bridger Glade Pump Station

-\$209	-1,140	-13%	-4,390	-149
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)
-\$806				-569
R12M Energy Cost Savings				R12M CO2e Savings (kg/yr)


Comments:

The electricity use baseline was updated for the Bridger Glade Pump Station, the baseline period is July 2021 to June 2022. The electricity baseline uses the amount of water pumped (m³) as the independent variable. The updated baseline has no baseload factor and a marginally larger variable component.

Months of high demand have typically used more electricity than expected. This may indicate that during periods of high demand the pump station is operating outside of its best efficiency point.


August 2022 electricity usage is more than expected, the monthly EUI has also increased. This could indicate that the pumps are operating outside of their best efficiency point.


Bridger Glade Pumps Electricity Use Compared to Baseline (kWh)






Bridger Glade Pump Station











Bridger Glade Pump Station





● EUI Monthly (kWh/m^3) ● EUI R12M (kWh/m^3)



Ohope Oxidation Ponds


-\$183	-1,020	-6%	-320 R12M Electricity Savings (kWh/yr)	-134
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)		CO2e Savings (kg/mo)
-\$57 R12M Energy Cost Savings				-49 R12M CO2e Savings (kg/yr)

Comments:

The baseline for electricity use was updated for the Ohope Oxidation Ponds, the baseline period is July 2021 to June 2022. The electricity baseline uses the amount of effluent pumped (m^3) as the independent variable. The updated baseline has a larger baseload factor and a smaller variable component.

Electricity use has been more than expected in July and August 2022. July 2022's EUI was less than expected and August 2022's monthly EUI is more than expected, the average of these two months is close to the EUI over the past 12 months.


Ohope Oxidation Ponds Electricity Use Compared to Baseline (kWh)






Ohope Oxidation Ponds











Ohope Oxidation Ponds

Ohope Oxidation Ponds Energy Use Index by Month Compared to Rolling 12-Month Values






Whakatane Oxidation Ponds

-\$734	-3,754	-8%	36,052	-492	
Monthly Energy Cost Savings	Elec. Savings (kWh/mo)	Elec. Savings (%)	R12M Electricity Savings (kWh/yr)	CO2e Savings (kg/mo)	
\$4,980				4,616	
R12M Energy Cost Savings				R12M CO2e Savings (kg/yr)	

Comments:

The electricity use baseline was updated for the Whakatane Oxidation Ponds, the baseline period is July 2021 to June 2022. The electricity baseline combines electricity use for the NHH and TOU account and uses the effluent volumes each month (m^3) as the independent variable. The updated baseline has a smaller baseload factor and a smaller variable component.

The past three months have used more electricity than expected, which may have some interaction with rainfall, however, monthly rainfall in August 2022 was less than average. The EUI has decreased for the past three months, which is expected due to the relatively large baseload and higher pumping demands.




R12M Cost Savings (\$/year)




Whakatane District Council

Whakatane Oxidation Ponds













Whakatane Oxidation Ponds





● EUI Monthly (kWh/m^3) ● EUI R12M (kWh/m^3)




McAlister Street and Rose Garden Pump Stations

-\$234 Monthly Energy Cost Savings	-2,917 Elec. Savings (kWh/mo)	-63% Elec. Savings (%)	9,487 R12M Electricity Savings (kWh/yr)	-382 CO2e Savings (kg/mo)
\$5,081 R12M Energy Cost Savings				1,204 R12M CO2e Savings (kg/yr)

Comments:

The baseline for McAlister St and Rose Garden Pumps was updated, the baseline adjusts for the amount of rainfall at the Kopeopeo weather station. Expected electricity is for McAlister St and Rose Gardens combined. The baseline period uses data from July 2021 to June 2022. The updated baseline uses a smaller baseload and a marginally smaller variable component.

Electricity used for the month was 63% more than expected. Rainfall was down from June and July, with greater than 200mm of rain per month. Rainfall in August was approximately 65mm. Increases in electricity use are primarily from the McAlister Street Pump Station.





McAlister Street and Rose Garden Pump Stations



