

Construction Statement

Installation of Solid Fuel Heater – PS3

Installer Company / Name: _____ Building Consent Number: _____

Certified Installer /Registration Number: _____

Make and Model of Fire: _____ Serial Number: _____

Free Standing ☐ Inbuilt ☐ Wetback ☐

Plumbers Name and Registration Number (if wetback installed): _____

Owner's Name: _____

Site Address: _____

It is confirmed that for the installation the following checks were taken and Completed (tick as appropriate):

| | Y | N | N/A |
|--|---|---|-----|
|--|---|---|-----|

| | | | |
|--|--------------------------|--------------------------|--------------------------|
| Smoke alarms have been installed within 3 metres of each bedroom and on every level of the building: | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
|--|--------------------------|--------------------------|--------------------------|

| | | | |
|--|--------------------------|--------------------------|--------------------------|
| The flashing has been installed as per the approved BC and is weather tight: | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
|--|--------------------------|--------------------------|--------------------------|

| | | | |
|--|--------------------------|--------------------------|--------------------------|
| The flue extends 600mm above the ridge if within 3m: | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
|--|--------------------------|--------------------------|--------------------------|

| | | | |
|--------------------------------------|--------------------------|--------------------------|--------------------------|
| Seismic restraints have been fitted: | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
|--------------------------------------|--------------------------|--------------------------|--------------------------|

| | | | |
|---|--------------------------|--------------------------|--------------------------|
| Flue sealed and fixed with stainless steel fasteners and fixed to heating unit: | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
|---|--------------------------|--------------------------|--------------------------|

| | | | |
|---|--------------------------|--------------------------|--------------------------|
| Hearth measurements checked in accordance with manufacturer's specifications: | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
|---|--------------------------|--------------------------|--------------------------|

Free standing installation

| | | | |
|--|--------------------------|--------------------------|--------------------------|
| Outer liner used and extends below ceiling lining: | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
|--|--------------------------|--------------------------|--------------------------|

| | | | |
|--|--------------------------|--------------------------|--------------------------|
| Inner Liner used in ceiling and extended 200mm above roof penetration: | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
|--|--------------------------|--------------------------|--------------------------|

| | | | |
|--|--------------------------|--------------------------|--------------------------|
| Support stays installed if flue extends more than 1500mm from penetration: | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
|--|--------------------------|--------------------------|--------------------------|

| | | | |
|---|--------------------------|--------------------------|--------------------------|
| Structural integrity of roof framing not compromised: | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
|---|--------------------------|--------------------------|--------------------------|

| | | | |
|--|--------------------------|--------------------------|--------------------------|
| Photos of roof space framing supplied: | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
|--|--------------------------|--------------------------|--------------------------|

| | | | |
|--|--------------------------|--------------------------|--------------------------|
| Has a flue shield been fitted if required: | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
|--|--------------------------|--------------------------|--------------------------|

PS001

VERSION 1

7/02/2018

Inbuilt Installation

All cracks in masonry cavity filled with fire resistant sealant or matting: ☐ ☐ ☐

No exposed timber in cavity: ☐ ☐ ☐

Mantle height checked and mantle deflector installed if too low: ☐ ☐ ☐

I _____ (installer's name) confirm that the above specified installation has been installed in accordance with the approved building consent documentation and manufacturer's specifications and complies with Standard AS/NZS 2918:2001 and the provisions of the New Zealand building code. I understand that the Whakatāne District Council is reliant on this construction statement in order to establish compliance with the requirements of the Building Act 2004, Building code and consented plans and will use this statement as part of the grounds to issue the code compliance certificate for this application.

Signature: _____

Date: _____